

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 01/2025-26

Dated: 27/05/2025

It is certified that an inspection team headed by Dr. Zafaryab Faruk, (M.O Grade - I)

(Name of Officers with designation) from Community health centre, Behrorabad PHED

inspected the Wisdom International Public School, Mahadevpuram Phase -1, Sidcul Haridwar

(Name & Address of the school) on 27/05/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no 274/UJS/DLWQTML/2025-26 dated 21/05/2025 of

District Level Water Quality Testing and Monitoring Laboratory (PHED Lab) certified

that the Wisdom International Public School (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 27/05/2026

Signature with Seal:

Name

Zafar

DR. ZAFARYAB FARUK

Designation

MEDICAL OFFICER GRADE - I

Name & Address of the Office / Department :

CHC BANARABAD, MEDICAL  
HEALTH AND FAMILY WELFARE  
Zafar UTTARAKHAND  
चिकित्सा अधिकारी  
सामुदायिक केन्द्र-बनारबाद  
हरिद्वार

To

Managing Director

Wisdom International Public School

Mahadevpuram Phase - 1 Sidcul

Haridwar

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

[Signature]  
**PRINCIPAL**  
WISDOM INTERNATIONAL PUBLIC SCHOOL  
SIDCUL, HARIDWAR (U.K.)

[Signature]  
**MANAGER**  
WISDOM INTERNATIONAL PUBLIC SCHOOL  
SIDCUL, HARIDWAR (U.K.)



**District Level Water Quality Testing and Monitoring Laboratory**  
**Uttarakhand Jal Sansthan, Jalkal Mayapur, Haridwar**  
 Ph (O): 0134-226360, E-mail: [eeujshrd@yahoo.com](mailto:eeujshrd@yahoo.com)

9



TC-12836

**TEST REPORT**

|   |  |                     |                                    |
|---|--|---------------------|------------------------------------|
| Name and Address of Organization/<br>Customer | Wisdom International Public School, Mahadevpuram Phase -01 Sidcul Haridwar |                     |                                    |
| Test Report ID                                | 274/UJS/DLWQTML/2025-26  | Reporting Date      | 21/05/2025                         |
| ULR No.                                       | TC128362400000114F   | Sample Location     | Wisdom International Public School |
| Product Description                           | Drinking Water   | Sample Collected by | Customer                           |
| Reference Sample Identification:              | DLWQTML/UJS/2025-274   |                     |                                    |
| Date of Start of Analysis:                    | 19/05/2025   |                     |                                    |
| Date of End of Analysis:                      | 20/05/2025   |                     |                                    |
| Date and Time of Sample Received:             | 19/05/2025 & 12:15 pm  |                     |                                    |

| SN  | Parameters  | Test Method  | Result      | Acceptable Limit<br>As per<br>( IS10500:2012) | Permissible Limit<br>(IS 10500:2012)<br>in the<br>Absence of<br>alternative source |
|-----|---|--|-------------|---|--|
| 1.  | pH at 25°C  | IS 3025 (Part 11) 2022.  | 6.98        | 6.5 to 8.5                                    | No Relaxation  |
| 2.  | Total Dissolved Solids (TDS), at 180°C<br>mg/L, Max | IS 3025 (Part 16), 2023  | 352         | 500   | 2000   |
| 3.  | Turbidity, NTU, Max                                 | IS 3025 (Part 10), 2023  | 0.39        | 1   | 5  |
| 4.  | Total Alkalinity (as CaCO <sub>3</sub> ), mg/L, Max | IS 3025 (Part 23), 2023  | 182         | 200   | 600  |
| 5.  | Total Hardness (as CaCO <sub>3</sub> ), mg/L, Max   | IS 3025 (Part 21), 2009  | 148         | 200   | 600  |
| 6.  | Calcium as Ca, mg/l                                 | IS 3025 ( Part 40), 2019   | 49.6        | 75  | 200  |
| 7.  | Chloride, mg/L, Max                                 | IS 3025 (Part 32), 2019  | 7           | 250   | 1000   |
| 8.  | Magnesium as Mg, mg/l                               | APHA 24 <sup>th</sup> Ed -3500-Mg<br>Method B:2023<br>(Calculation Method) | 5.83        | 30  | 100  |
| 9.  | Colour, Hazen, Max                                  | IS 3025 (Part 4): 2021   | Less than 1 | 5   | 15   |
| 10. | Odour   | IS 3025 (Part 5) : 2018  | Agreeable   | Agreeable                                     | Agreeable  |

**Note:**

- The results listed refer only to tested sample and applicable parameters.
- This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
- The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
- The results apply to the sample as received
- The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

\*\*\*\* End of Report\*\*\*\*

*[Signature]*

**PRINCIPAL**

WISDOM INTERNATIONAL PUBLIC SCHOOL  
SIDCUL, HARIDWAR (U.K.)

*[Signature]*

(Er. Anjali Palariya)

Review and Authorized By  
Authorized Signatory,  
District Water Quality Testing Monitoring

District Water Quality Testing Monitoring  
Laboratory,

*[Signature]*  
**MANAGER**

WISDOM INTERNATIONAL PUBLIC SCHOOL  
SIDCUL, HARIDWAR (U.K.)



**District Level Water Quality Testing and Monitoring Laboratory**  
**Uttarakhand Jal Sansthan, Jalkal Mayapur, Haridwar**  
Ph (O): 0134-226360, E-mail: [eeujshrd@yahoo.com](mailto:eeujshrd@yahoo.com)

**TEST REPORT**

|   |  |                     |                                    |
|---|--|---------------------|------------------------------------|
| Name and Address of Organization/<br>Customer | Wisdom International Public School, Mahadevpuram Phase -01 Sidcul Haridwar |                     |                                    |
| Test Report ID                                | 274/UJS/DLWQTML/2025-26  | Reporting Date      | 21/05/2025                         |
|   |  | Sample Location     | Wisdom International Public School |
| Product Description                           | Drinking Water   | Sample Collected by | Customer                           |
| Reference Sample Identification:              | DLWQTML/UJS/2025-274   |                     |                                    |
| Date of Start of Analysis:                    | 19/05/2025   |                     |                                    |
| Date of End of Analysis:                      | 20/05/2025   |                     |                                    |
| Date and Time of Sample Received:             | 19/05/2025 & 12:15 pm  |                     |                                    |

| SN | Parameters                 | Test Method          | Results | Acceptable Limit<br>As per<br>(IS10500:2012) | Permissible Limit<br>(IS 10500:2012)<br>in the<br>Absence of<br>alternative source |
|----|----------------------------|----------------------|---------|--|--|
| 1  | Total Coliform, MPN/ 100ml | APHA 23rd Ed.-9223-B | Absent  | Absent                                       | Absent   |
| 2  | E. coli, MPN/ 100ml        | APHA 23rd Ed.-9223-B | Absent  | Absent                                       | Absent   |

**Note:**

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

\*\*\*\* End of Report\*\*\*\*

  
District Water Quality Testing Monitoring  
Laboratory,  
Uttarakhand Jal Sansthan, Haridwar

  
**MANAGER**  
WISDOM INTERNATIONAL PUBLIC SCHOOL  
SIDCUL, HARIDWAR (U.K.)

  
(Er. Anjali Palariya)

Review and Authorized By  
Authorized signatory,  
District Water Quality Testing Monitoring  
Laboratory,  
Uttarakhand Jal Sansthan, Haridwar

  
**PRINCIPAL**  
WISDOM INTERNATIONAL PUBLIC SCHOOL  
SIDCUL, HARIDWAR (U.K.)