

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. school/sanit/2026- 27/1

Date 30 -07 -2026

It is Certified that an inspection team headed by Dr. Hemant kumar Medical Officer from Community Health Center Bahadrabad Haridwar inspected the WISDOM INTERNATIONAL PUBLIC SCHOOL Mahadevpuram, phase-1 SIDCUL Haridwar Uttarakhand on 29-07-2026 and found that the **WISDOM INTERNATIONAL PUBLIC SCHOOL** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above Valid for a period of one year.

Signature with Seal

Name Dr. Hemant kumar

Designation Medical Officer

To,

WISDOM INTERNATIONAL PUBLIC SCHOOL

Mahadevpuram ,phase-1 SIDCUL .HARIDWAR

.....

(Name & Address of the Institution)


PRINCIPAL

WISDOM INTERNATIONAL PUBLIC SCHOOL
AFFILIATED TO CBSE NEW DELHI AFFL NO. 3538725
MAHADEVPURAM PHASE -1, SIDCUL HARIDWAR
UTTARAKHAND -249402, PH: 01334 - 297388


MANAGER

WISDOM INTERNATIONAL PUBLIC SCHOOL
SIDCUL, HARIDWAR (U.K.)



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Jalkal Mayapur, Haridwar
Ph (O): 01334-226360, E-mail: eeujshrd@yahoo.com

TEST REPORT

Name and Address of Organization/ Customer	Wisdom International Public School, Bhadrabad Block, Mahadevpuram, Haridwar.			
Test Report ID	63-1-15-DLWQTM-2026-27	Report Issue Date	19/06/2026	
Date and Time of Sample Received:	16/06/2026 & 14:00	Sample Location	Wisdom International Public School, Bhadrabad Block, Mahadevpuram, Haridwar.	
Product Description	Drinking Water	Sample Collected by	Farisq Pant	
Reference Sample Identification:	DLWQTM/UJS/2026-27/63	Duration of Analysis	16/06/2026 to 18/06/2026	

Sl	Parameters	Test Method	Result	Requirements (Acceptable Limit) As per (IS10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of altern
(A) Organoleptic and Physical Parameters					
1.	pH at 25°C	IS 3025 (Part 11): 2022	7.60	6.5 to 8.5	No Relaxation
2.	Total Dissolved Solids (TDS), at 180°C mg/L	IS 3025 (Part 16): 2023	300	500 Max	2000 Max
3.	Turbidity, NTU	IS 3025 (Part 10): 2023	0.10	1 Max	5 Max
4.	Colour, CU	IS 3025 (Part 4): 2021	5	5 Max	15 Max
5.	Odour	IS 3025 (Part 5): 2018	Agreeable	Agreeable	Agreeable
(B) General Parameters concerning substances					
6.	Total Alkalinity (as CaCO ₃), mg/L	IS 3025 (Part 23): 2023	200	200 Max	600 Max
7.	Total Hardness (as CaCO ₃), mg/L	IS 3025 (Part 21): 2009	202	200 Max	600 Max
8.	Calcium as Ca, mg/l	IS 3025 (Part 40): 2019	53.6	75 Max	200 Max
9.	Chloride as Cl, mg/L	IS 3025 (Part 32): 2025	12.5	250 Max	1000 Max
10.	Magnesium as Mg, mg/l	IS 3025: (Part 46): 2023 (Volumetric Analysis EDTA)	16.524	30 Max	100 Max

Note:

- The results listed refer only to tested sample and applicable parameters.
- This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing Laboratory.
- The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
- The results apply to the sample as received
- The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

(Er. Rakesh Chandra Bamrara)
Lab Incharge

प्राप्त कला अभियन्ता
सहसंचालक प्रमाण

MANAGER

WISDOM INTERNATIONAL PUBLIC SCHOOL
SIDCUL, HARIDWAR (U.K.)

WISDOM INTERNATIONAL PUBLIC SCHOOL
AFFILIATED TO CBSE NEW DELHI AFF. NO. 3530725
MAHADEVPURAM PHASE -1, SIDCUL HARIDWAR
UTTARAKHAND -249402, PH: 01334 - 297380



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand JalSansthan, Jalkal Mayapur, Haridwar
Ph (O): 0134-226360, E-mail: eeujshrd@yahoo.com

TEST REPORT

Name and Address of Organization/ Customer	Wisdom International Public School, Bhadrabad Block, Mahadevpuram, Haridwar.			
Test Report ID	63/ UJS/DLWQ1ML/2026-27	Report Issue Date	19/06/2026	
Date and Time of Sample Received:	16/06/2026 & 14:00	Sample Location	Wisdom International Public School, Bhadrabad Block, Mahadevpuram, Haridwar.	
Product Description	Drinking Water	Sample Collected by	Tanishq Pant	
Reference Sample Identification:	DLWQ1ML/UJS/2026-27/63	Duration of Analysis	16/06/2026 to 18/06/2026	
Parameters	Test Method	Results	Acceptable Limit As per (IS10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
1. Residual Free Chlorine, mg/L, Min	IS 3025Pt-26:1986	NA	0.2	1.0
Bacteriological Parameters				
2. Total Coliform, MPN/ 100ml	IS 15185:2016 Refl 2021	Absent	Absent	Absent
3. E. coli, MPN/ 100ml	IS 15185:2016 Refl 2021	Absent	Absent	Absent

Note:

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not to be reproduced wholly or in parts for promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received.
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer.

**** End of Report****

(Er. Rakesh Chandra Bamrara)
Lab Incharge

जल कल अभियन्ता
उत्तराखण्ड जल संस्थान
हरिद्वार

WISDOM INTERNATIONAL PUBLIC SCHOOL
AFFILIATED TO CBSE NEW DELHI AFFI. NO. 3530725
MAHADEVPURAM PHASE -1, SIDCUL HARIDWAR
UTTARAKHAND -249402, PH: 01334 - 297380

MANAGER
WISDOM INTERNATIONAL PUBLIC SCHOOL
SIDCUL, HARIDWAR (U.K.)